

FEDERAL ENERGY REGULATORY COMMISSION
Office of Energy Projects
Division of Dam Safety and Inspections – Chicago Regional Office
Federal Building - 230 South Dearborn Street, Room 3130
Chicago, Illinois 60604
(312) 596-4430 Office - (312) 596-4460 Facsimile

In reply, refer to: Project No. 10856

September 29, 2016

Mr. Jason Kreuzscher
Vice President, Operations
Renewable World Energies, LLC
100 South State Street, P.O. Box 264
Neshkoro, WI 54960

Re: Penstock Vacuum Breaker Installation
Au Train Hydroelectric Project (P-10856)

Dear Mr. Kreuzscher:

We have completed our review of July 15, 2016 Progress Report for the installation of the penstock vacuum breakers at your Au Train Hydroelectric Project (P-10856). The new vacuum breakers were installed since the old vacuum breakers failed this past winter leading to a collapse of the penstock. You are reminded the proper winter protection should be installed and monitored to reduce the potential of the new vacuum breakers from also failing.

Please contact me at (312) 596-4430 or Mr. Peter Chapman, P.E. at (312) 596-4446 if you have any questions.

Sincerely,

John A. Zygaj, P.E.
Regional Engineer

Document Content(s)

10856_AuTrain_penstock vacuum breaker_37471.PDF.....1-1